

GOVT. COLLEGE OF ENGINEERING AND RESEARCH, AWASARI

Awasari(Khurd) Tal: Ambegaon, Dist.Pune-412 405

Tel. No.02133-230582, E-Mail – gcoeara@gmail.com, Website : www.gcoeara.ac.in

No. GCOEARA/Store/2017-18/ 1163

Date:

To,
HOD- Computer Engineering for display on College Website

21 MAR 2018

Subject : Quotation for supply of Alternator.

Please send your quotation for the following items on the terms and conditions listed below, mentioning our reference letter number, date and due date of quotation on your sealed envelope on or before **31.03.2018** at 5.00 pm.

Sr.No.	Specification	Qty.	Unit
1	10 KVA Alternator, power output-10 KVA/8KW, Phase-3, Voltage-440V, RPM- 1500, PF- 0.8, Conn.- Star, INS. Class- H, C/S- 50, AMB °C- 40, Duty- S1, EFF. %- 80-85, Screen protected drip proff with enclosure conforming to protection IP 23, Horizontal foot mounted (B3) 1500 RPM, 4 pole 0.8 PF (lag), voltage regulation +/-5% double bearing suitable for operations upto 40 Deg C Ambient Temperature & 1000 mtr altitude.	1	No.

Terms & Conditons

- 1 Taxes – Inclusive / if extra clearly mention the percentage.
- 2 Delivery period –
- 3 Payment Terms –
- 4 Quotation Validity –
- 5 Warranty -
- 6 Guaranty-
- 7 Delivery Charges – Free / if extra mention clearly.
- 8 The part supply and its bill will strictly not be entertained.
- 9 If you fail to supply the stores within the specified period, the order will be treated at cancelled without any information.
- 10 The material will be accepted subject at approval(after inspection of the material),If rejected it will be returned to you at your cost.
- 11 The material to be supplied should be strictly according to the specification only.
- 12 Octroi is not applicable since Institute is located in Gram Panchayat area.
- 13 Please attach copy of your shop registration certificate and **GST Registration Number** alongwith your quotation, without which your quotation will not be accepted.



(Dr. A.S. Pant)
Principal

Govt.College of Engineering & Research Awasari
Awasari(khurd)