



महाराष्ट्र शासन

# शासकीय अभियांत्रिकी व संशोधन महाविद्यालय,

अवसरी (खु.) ता.आंबेगाव जि.पुणे - 412 405



दूरध्वनी क्र. 02133 - 225900

फॅक्स क्र. 02133 - 225901

ई-मेल - [gcoeara@gmail.com](mailto:gcoeara@gmail.com)

वेबसाईट : [www.gcoeara.ac.in](http://www.gcoeara.ac.in)

जा.क्र.शाअसंमअ/निविदा मुदतवाढ/2024/2008

दि. / / 2024

16 JUL 2024

## परिपत्रक :-

**विषय : Automatic Power Factor Controller (APFC Pnael) बसविणे कामाच्या निविदेस मुदतवाढ देणे बाबत.**

संदर्भ : निविदा सुचना GCOEARA/Store/2024/1844 दि.29/06/24

उपरोक्त विषयाबाबत नमुद करण्यात येते की, संदर्भानुसार संस्थेतीकरीता पाणीपुरवठा करणारी विहरी वर **Automatic Power Factor Controller (APFC Pnael)** बसविणे या कामाकरीता नोंदणीकृत पुरवठादार/कंत्राटदारा मार्फत मोहरबंद निविदा मागविण्यात आलेल्या होत्या. सदर निविदा सुचनेस प्रतिसाद न मिळाल्यामुळे निविदा स्विकारणेस दि. 23/07/2024 पर्यंत मुदतवाढ देण्यात येत आहे. निविदा सादर केलेल्या निविदाकारांनी पुन्हा निविदा सादर करण्याची आवश्यकता नाही. सोबत संदर्भीय निविदेची छायांकित प्रत जोडली आहे.

(डॉ. डी.आर. पानगव्हाणे)

प्र.प्राचार्य,

शासकीय अभियांत्रिकी व संशोधन महा.  
अवसरी खु. ता.आंबेगाव जि.पुणे.

प्रत : Prof.R.P. Bagwade /Mr. A.D.Chavan यांना संस्थेच्या संकेतस्थळावर प्रदर्शित करण्याकरीता.





Govt. of Maharashtra

**GOVT. COLLEGE OF ENGINEERING AND RESEARCH, AWASARI**

Awasari(Khurd) Tal: Ambegaon, Dist.Pune-412 405

Tel. No.02133-225900

E-Mail – gcoeara@gmail.com

Website : www.gcoeara.ac.in

No. GCOEARA/Store/2024/ 1844

Date:

To,  
As per addresses overleaf

29 JUN 2024

**Subject : Quotation for supply of Automatic Power Factor Controller - APFC Panel.**

Please send your quotation for the following items on the terms and conditions listed below, mentioning our reference letter number, date and due date of quotation on your sealed envelop, on or before 15-07-2024 at 4.00 pm.

Sr. No	Specifications	Qty	Total
1	APFC Panel Main Incomer - 3 Pole, MCCB Suitable Rated Amp with Suitable kA Rating. Separate neutral Link	1 Set with installation	
	Individual Step Protection - 3 Pole, MCB, Suitable Rated Amp, C Curve		
	Individual Step Switching - 3 Pole, Power Contactors, Derated for Capacitor Duty.		
	Individual Step Capacitors - 3 Phase, Delta Connected, Normal Duty Phi Cap Model, MPP Round Type Capacitors		
	APFC Relay - Truly Intelligent, 3 Phase Current Sensing APFC Relay,		
	Material With Panel - 4 Core AL Armoured Power Cable with Lugs 3 Meters, 1 No. Sensing CTs with Suitable Ratio, 2 Core CU Flexible Cable for CT Sensing 3 Meters, Wall Mounting Misc. Hardware etc.		
	APFC Panel Powder Coated with Wall Mounting Arrangement		

**Terms & Conditions**

- Taxes – Inclusive / if extra clearly mention the percentage.
  - Delivery period –
  - Payment Terms –
  - Quotation Validity –
  - Warranty -
  - Guaranty-
- } Mention clearly
- Delivery Charges – Free / if extra mention clearly.
  - The part supply / work and its bill will strictly not be entertained.
  - If you fail to supply the stores within the specified period, the order will be treated at cancelled without any information.
  - The material will be accepted subject at approval(after inspection of the material),If rejected it will be returned to you at your cost.
  - The material to be supplied should be strictly according to the specification only.
  - Octroi is not applicable since Institute is located in Gram Panchayat area.
  - Please attach copy of your Shop Registration Certificate and GST Registration Certificate along with your quotation, without which your quotation will not be accepted.
  - Before submitting the quotation of the above work interested vendor can understand the nature of work and the actual work and submit the quotation accordingly. Interested suppliers can visit the organization during office hours from 27-06-2024 to 06-07-2024. (Both days inclusive)
  - Payment will be issue on after satisfactory completion of work.

*(Dr. D. R. Pangavhane)*  
(Dr. D. R. Pangavhane)

I/c Principal

Govt.College of Engineering & Research Awasari

Awasari(khurd) Tal: Ambegaon, Dist.Pune

*APC (A.S. Manu)*  
O/C

*Rajni B. Kulkarni*

*29.06.24*  
*(Dr. D. R. Pangavhane)*